

Fireworks - Tent Checklist (5-17-11)			FWT ID Number				
1	IC 22-11-14-4.5(a)(1)	The tent may not be larger than one thousand five hundred (1,500) square feet.					
2	IC 22-11-14-4.5(a)(2)	There may be only one (1) tent for each registration granted under section 11(a) of this chapter.					
3	IC 22-11-14-4.5(a)(3)	The tent may not be located closer than one hundred (100) feet from a permanent structure.					
4	IC 22-11-14-4.5(a)(4)	A vehicle may not be parked closer than twenty (20) feet from the edge of the tent.					
5	IC 22-11-14-4.5(a)(5)	The tent must be flame retardant.					
6	IC 22-11-14-4.5(a)(7)	Sales of fireworks may be made from the tent for not more than forty-five (45) days in a year.					
7	IC 22-11-14-4.5(a)(8)	The weight of consumer fireworks in a tent may not exceed three thousand (3,000) gross pounds of consumer fireworks.					
8	IC 22-11-14-7(a)	A retailer selling items referenced in section 8(a) of this chapter at one (1) or more temporary stands must obtain a fireworks stand retail sales permit, referred to in this section as a "permit", from the state fire marshal.					
9	IC 22-11-14-7(d)	The permit shall be posted by the retailer at the retail sales stand so that it is easily seen by the public. However, the state fire marshal's issuance of a permit does not constitute approval of the fireworks offered for sale by the retailer. The retailer is responsible for determining that all fireworks which the retailer offers for sale conform to applicable law.					
10	IC 22-11-14-7(f)	Fireworks may not be sold at retail from a motor vehicle (as defined in IC 9-13-2-105).					
11	IC 22-11-14-8(a)	<p>A person shall not sell at retail, offer for sale at retail, or deliver the following items to a person less than eighteen (18) years of age:</p> <ul style="list-style-type: none"> (1) Dipped sticks or wire sparklers. However, total pyrotechnic composition may not exceed one hundred (100) grams per item. Devices containing chlorate or perchlorate salts may not exceed five (5) grams in total composition per item. (2) Cylindrical fountains. (3) Cone fountains. (4) Illuminating torches. (5) Wheels. (6) Ground spinners. (7) Flitter sparklers. (8) Snakes or glow worms. (9) Smoke devices. (10) Trick noisemakers, which include: <ul style="list-style-type: none"> (A) Party poppers. (B) Booby traps. (C) Snappers. (D) Trick matches. (E) Cigarette loads. (F) Auto burglar alarms. 					
12	IC 22-11-14-8(b)	A retailer or wholesaler of consumer fireworks may sell consumer fireworks to a person at least eighteen (18) years of age.					
13	IC 22-11-14-8(c)	An individual who sells consumer fireworks must be at least eighteen (18) years of age.					
14	IC 22-11-14-8(d)	An individual who sells an item set forth in subsection (a) must be at least sixteen (16) years of age.					

15	675 IAC 22-2.4 Sec. 308.2 2008 Edition IFC	A person shall not take or utilize an open flame or light in a structure, vessel, boat or other place where highly flammable, combustible or explosive material is utilized or stored. Lighting appliances shall be well-secured in a glass globe and wire mesh cage or a similar approved device.					
16	675 IAC 22-2.4 Sec. 906.1 2008 Edition IFC	Portable fire extinguishers shall be installed where required by TABLE 906.1 and where required by local ordinance.					
17	675 IAC 22-2.4 Sec. 1028.2 2008 Edition IFC	Required exit accesses, exits or exit discharges shall be continuously maintained free from obstructions or impediments to full instant use in the case of fire or other emergency when the areas served by such exits are occupied. Security devices affecting means of egress shall be approved by the fire code official.					
18	675 IAC 22-2.4 Sec. 1028.5 2008 Edition IFC	Furnishings, decorations or other objects shall not be placed so as to obstruct exits, access thereto, egress therefrom, or visibility thereof. Hangings and draperies shall not be placed over exit doors or otherwise be located to conceal or obstruct an exit. Mirrors shall not be placed on exit doors. Mirrors shall not be placed in or adjacent to any exit in such a manner as to confuse the direction of exit.					
19	675 IAC 22-2.4 Sec. 2403.12.6 2008 Edition IFC	Exits shall be clearly marked. Exit signs shall be installed at required exit doorways and where otherwise necessary to indicate clearly the direction of egress when the exit serves an occupant load of 50 or more.					
20	675 IAC 22-2.4 Sec. 2403.12.6.1 2008 Edition IFC	Exit signs shall be of an approved self-luminous type or shall be internally or externally illuminated by luminaires supplied in the following manner: 1. Two separate circuits, one of which shall be separate from all other circuits, for occupant loads of 300 or less; or 2. Two separate sources of power, one of which shall be an approved emergency system, shall be provided when the occupant load exceeds 300. Emergency systems shall be supplied from storage batteries or from the on-site generator set, and the system shall be installed in accordance with the ICC Electrical Code.					
21	675 IAC 22-2.4 Sec. 2403.12.7 2008 Edition IFC	Means of egress illumination shall be installed at required exit doorways and where otherwise necessary to indicate clearly the direction of egress when the exit serves an occupant load of 50 or more. Means of egress shall be illuminated with light having an intensity of not less than one foot-candle (11 lux) at floor level while the structure is occupied. Fixtures required for means of egress illumination shall be supplied from a separate circuit or source of power.					
22	675 IAC 22-2.4 Sec. 2403.12.8 2008 Edition IFC	The required width of exits, aisles and passageways shall be maintained at all times to a public way. Guy wires, guy ropes and other support members shall not cross a means of egress at a height of less than 8 feet (2438 mm). The surface of means of egress shall be maintained in an approved manner.					
23	675 IAC 22-2.4 Sec. 2404.6 2008 Edition IFC	Smoking shall not be permitted in tents, canopies or membrane structures. Approved "No Smoking" signs shall be conspicuously posted in accordance with Section 310.					
24	675 IAC 22-2.4 Sec. 2404.11 2008 Edition IFC	There shall be a minimum clearance of at least 3 feet (914 mm) between the fabric envelope and all contents located inside the tent or membrane structure.					
25	675 IAC 22-2.4 Sec. 2404.15 2008 Edition IFC	Heating and cooking equipment shall be in accordance with Sections 2404.15.1 through 2404.15.7.					
26	675 IAC 22-2.4 Sec. 2404.15.1 2008 Edition IFC	Heating or cooking equipment, tanks, piping, hoses, fittings, valves, tubing and other related components shall be installed as specified in the International Mechanical Code and the International Fuel Gas Code, in effect at the time the equipment is installed.					

27	675 IAC 22-2.4 Sec. 2404.15.2 2008 Edition IFC	Gas, liquid and solid fuel-burning equipment designed to be vented shall be vented to the outside air as specified in the International Fuel Gas Code and the International Mechanical Code, in effect at the time the equipment is installed. Such vents shall be equipped with approved spark arresters having openings not exceeding one-fourth (1/4) inch (six and four-tenths (6.4) mm) wire mesh. Where vents or flues are used, all portions of the tent, canopy or membrane structure shall be not less than 12 inches (305 mm) from the flue or vent.					
28	675 IAC 22-2.4 Sec. 2404.15.3 2008 Edition IFC	Cooking and heating equipment shall not be located within 10 feet (3048 mm) of exits or combustible materials.					
29	675 IAC 22-2.4 Sec. 2404.15.4 2008 Edition IFC	Operations such as warming of foods, cooking demonstrations and similar operations that use solid flammables, butane or other similar devices which do not pose an ignition hazard, shall be approved.					
30	675 IAC 22-2.4 Sec. 2404.15.5 2008 Edition IFC	<p>(1) Temporary membrane structures, tents, and canopies where open or exposed flame equipment is used for cooking shall comply with Section 2404.7.</p> <p>(2) Temporary membrane structures, tents, and canopies where open or exposed flame cooking is performed shall be separated from other temporary membrane structures, tents, canopies, air-inflated, air-supported, and tensioned membrane structures, buildings, parked vehicles, or internal combustion engines by a minimum distance of 10 feet.</p> <p>(3) Cooking that produces grease-laden vapors is permitted in temporary membrane structures, tents, or canopies when commercial food heat-processing appliances are used that are listed and installed in accordance with Sections 2404.15.1 and 2404.15.2.</p> <p>(4) When open or exposed flame cooking equipment, other than commercial food heat-processing appliances, is used, surfaces subject to oil or grease deposits shall be cleaned at intervals frequently enough to prevent oil or grease deposits from exceeding a thickness of twenty-five thousandths (0.025) inch.</p> <p>(5) Cooking that does not use open or exposed flame cooking equipment may be performed in tents, canopies, and temporary membrane structures that comply with Section 2404.2.</p>					
31	675 IAC 22-2.4 Sec. 2404.15.6 2008 Edition IFC	Outdoor cooking that produces sparks shall not be performed within 10 feet of a temporary membrane structure, tent, canopy, air-inflated, air-supported, or tensioned membrane structure.					
32	675 IAC 22-2.4 Sec. 2404.15.7 2008 Edition IFC	Electrical cooking and heating equipment shall comply with the ICC Electrical Code.					
33	675 IAC 22-2.4 Sec. 2404.17.1 2008 Edition IFC	Flammable-liquid-fueled equipment shall not be used in tents, canopies or membrane structures.					